

# Certificate of Accreditation



## Water Hygiene Centre Ltd

Inspection Body No. 7826

**is accredited as a Type C body in accordance with International Standard ISO/IEC 17020:2012 - Conformity assessment – Requirements for the operation of various types of bodies performing inspection**

This accreditation demonstrates technical competence for a defined scope specified in the schedule to this certificate, and the operation of a management system (refer joint ISO-ILAC-IAF Communiqué dated September 2013). The schedule to this certificate is an essential accreditation document and from time to time may be revised and reissued.

The most recent issue of the schedule of accreditation, which bears the same accreditation number as this certificate, is available from [www.ukas.com](http://www.ukas.com).

This accreditation is subject to continuing conformity with United Kingdom Accreditation Service requirements.

A handwritten signature in blue ink, reading "Matt Gantley", is positioned above a horizontal line.

**Matt Gantley**, *Chief Executive Officer*  
United Kingdom Accreditation Service

Initial Accreditation: 13 April 2015  
Certificate Issued: 25 January 2024




Scan QR Code to  
verify

# Schedule of Accreditation

issued by

## United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <b>7826</b> <b>Type C</b> <b>Inspection Body</b>  Accredited to ISO/IEC 17020:2012	<b>Water Hygiene Centre Limited</b>  <b>Issue No: 009    Issue date: 21 March 2022</b>	
	<b>6 Southill Business Park</b> <b>Cornbury Park</b> <b>Charlbury</b> <b>Oxfordshire</b> <b>OX7 3EW</b>	<b>Contact: Mr Chris Lawry</b> <b>Tel: +44 (0)1993 840400</b> <b>E-Mail: Chris.Lawry@waterhygienecentre.com</b> <b>Website: www.waterhygienecentre.com</b>

Inspection performed at/from the above location only

### DETAIL OF ACCREDITATION

Field of Inspection	Type and Range of Inspection	Methods and Procedures
Legionella Risk Assessments	Artificial water risk system:	Documented In-House Methods, based on the requirements of ACoP L8: 2013 and BS 8580-1:2019
	<ol style="list-style-type: none"><li>1. Domestic hot / cold systems irrespective of size in premises</li><li>2. Spa baths and hydrotherapy pools in which warm water is deliberately agitated and re-circulated</li><li>3. Humidifiers and air washers which create a spray of water droplets and in which the water temperature is likely to exceed 20°C</li><li>4. Outlets generating a fine spray or aerosol i.e. sprays taps or hoses</li></ol>	In house method 1 (PDSRAP01)
	Water sampling for the purpose of Legionella risk assessments, for subsequent analysis; <i>Legionella spp</i> ,	In house method 2 (PDSSAP04)
	Water testing for the purpose of Legionella risk assessment: Temperature	In house method 3 (PDSHCP01)
Sampling and testing may be reported only as part of a risk assessment report in support of the Legionella risk assessment.		
END		